



# FLAMMABLES & COMBUSTIBLES

Hazard		Satisfactory	Needs Attention	Not Applicable	Target Date for Completion	Date Completed
1	Are combustible scrap, debris and waste materials (oily rags, etc.) stored in covered metal receptacles and removed from the work site promptly?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
2	Is proper storage practiced to minimize the risk of fire including spontaneous combustion?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
3	Are approved containers and tanks used for the storage and handling of flammable and combustible liquids?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
4	Are all connections on drums and combustible liquid piping, vapor and liquid tight?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
5	Are all flammable liquids kept in closed containers when not in use (e.g., parts cleaning tanks, pans, etc.)?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
6	Are bulk drums of flammable liquids grounded and bonded to containers during dispensing?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
7	Do storage rooms for flammable and combustible liquids have explosion-proof lights?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
8	Do storage rooms for flammable and combustible liquids have mechanical or gravity ventilation?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
9	Is liquefied petroleum gas stored, handled, and used in accordance with safe practices and standards?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
10	Are NO SMOKING signs posted on liquefied petroleum gas tanks?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
11	Are liquefied petroleum storage tanks guarded to prevent damage from vehicles?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
12	Are all solvent wastes, and flammable liquids kept in fire-resistant, covered containers until they are removed from the work site?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
13	Is vacuuming used whenever possible rather than blowing or sweeping combustible dust?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
14	Are fire separators placed between containers of combustibles or flammables, when stacked one upon another, to assure their support and stability?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
15	Are fire extinguishers selected and provided for the types of materials in areas where they are to be used? Class A-Ordinary combustible material fires. Class B - Flammable liquid, gas or grease fires. Class C - Energized-electrical equipment fires.	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
16	Are appropriate fire extinguishers mounted within 75 ft of outside areas containing flammable liquids and within 10 ft of any inside storage area for such materials?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
17	Are all extinguishers serviced, maintained and tagged at intervals not to exceed one year?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
18	Are extinguishers free from obstructions or blockage?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
19	Are all extinguishers fully charged and in their designated places?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		

20	Where sprinkler systems are permanently installed, are the nozzle heads so directed or arranged that water will not be sprayed into operating electrical switch boards and equipment?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
21	Are "NO SMOKING" signs posted where appropriate in areas where flammable or combustible materials are used or stored?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
22	Are safety cans used for dispensing flammable or combustible liquids at a point of use?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
23	Are all spills of flammable or combustible liquids cleaned up promptly?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
24	Are storage tanks adequately vented to prevent the development of excessive vacuum or pressure as a result of filling, emptying, or atmosphere temperature changes?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
25	Are storage tanks equipped with emergency venting that will relieve excessive internal pressure caused by fire exposure?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
26	Are "NO SMOKING" rules enforced in areas involving storage and use of hazardous materials?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
27	If a Halon 1301 fire extinguisher is used, can employees evacuate within the specified time for that extinguisher?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
28	Is the transfer/withdrawal of flammable or combustible liquids performed by trained personnel?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
29	Are employees trained in the use of fire extinguishers?	<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
30		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
31		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		
32		<input type="radio"/>	<input type="radio"/>	<input type="radio"/>		

\_\_\_\_\_

Name

\_\_\_\_\_

Date

**Actions Taken to Correct Items Checked as "Needs Attention"**

Hazard #	
Hazard #	
Hazard #	
Hazard #	
Hazard #	