

Emergency Shower

- Should provide room temperature water.
- Located in a well-lit area, within 10 seconds of free travel from chemical use.
- At 60" above the floor, the water pattern is at least 20" in diameter.
- Shower must deliver 20 gallons of water per minute for at least 15 minutes.
- Inspect and activate weekly to ensure good working condition and flush the lines.
- Instruct all employees on the location and use of shower.
- If provided, shower enclosure has a minimum diameter of 34".

